

**CARTERSVILLE FIRE DEPARTMENT**



**Temporary Consumer Fireworks Retail Sales (T-CFRS) Facilities:**

Name of Facility: \_\_\_\_\_  
 Address: \_\_\_\_\_  
 City: \_\_\_\_\_ State: \_\_\_\_\_ Zip: \_\_\_\_\_  
 Responsible Party: \_\_\_\_\_ Phone: \_\_\_\_\_  
 Area of Sales Floor: \_\_\_\_\_ sqft Area of Storage: \_\_\_\_\_ sqft  
 Open After Dusk Y \_\_\_ N \_\_\_ Interior Accessible to Public Y \_\_\_ N \_\_\_  
 Copy Certificate of Occupancy Provided Y \_\_\_ N \_\_\_

✓ = Pass, X = Fail, NA = Not applicable

**Status**

**DRAWING SUBMITTAL REQUIREMENTS**

- 1) Sites Plans showing the CFRS facility and detailing separation distances **[NFPA 1124 7.4.2]**
  - a. 20 ft from buildings. **[NFPA 1124 Table 7.4.7.2]**
  - b. 20ft from combustibles for tents, 10ft for stands and within 30ft of the retail area shall be clear of dry grass, dry shrubs, and combustible debris. **[NFPA 1124 Table 7.4.7.2]**
  - c. 20ft from other tents. **[NFPA 1124 Table 7.4.7.2]**
  - d. 10ft from vehicle parking. **[NFPA 1124 Table 7.4.7.2]**
  - e. 20ft from stands for tents, or 5ft for stands where aggregate area of multiple stands that are closer than 20ft is less than 800sqft. **[NFPA 1124 Table 7.4.7.2]**
  - f. 20ft from consumer fireworks storage. **[NFPA 1124 Table 7.4.7.2]**
  - g. 20ft from cooking equipment of any type **[NFPA 1124 7.4.9.3.1]**
  - h. 50ft from open flame cooking equipment **[NFPA 1124 7.4.9.3.2]**
  - i. 1000ft from a fire hydrant or FDC. **[25-10-2.6.B.ii]**
- 2) More than 125lbs (500lbs gross) weight or 250lbs (1000lbs gross) weight of fireworks when sprinkled **[NFPA 1124 7.3.1.1]**
  - a. Provide inventory list. **[NFPA 1124 7.3.24.2]**
- 3) Sidewall of tent or other defined perimeter of CFRS facility within 150ft of fire department access **[NFPA 1124 7.3.4]**
- 4) Located 50ft from motor vehicle fuel-dispensing station dispensers. **[NFPA 1124 7.3.12.2]**
- 5) Located minimum 300ft from any aboveground bulk storage or bulk dispensing area for flammable or combustible liquid, gas, or liquefied gas. **[NFPA 1124 7.3.12.6]**
- 6) Exits located such that travel distance does not exceed 75ft **[NFPA 1124 7.3.14.2]** 35ft in a temporary stand **[NFPA 1124 7.6.2.3.2]**
- 7) Floor plans showing minimum aisle width **[NFPA 1124 7.3.14.3.1.1]**
- 8) Portable fire extinguishers located such that the required travel distance to reach an extinguisher from any point not greater than 35ft. **[NFPA 1124 7.4.5.2]**, Temporary stands <200sqft only 1 fire extinguisher **[NFPA 1124 7.6.2.1]**
- 9) Construction details of retail shelves. **[NFPA 1124 7.3.3(6)]**

**TEMPORARY FACILITY MEANS OF EGRESS**

- 10) Evacuation plan posted in a conspicuous location for tents, canopies, and membrane structures **[NFPA 1124 7.4.8.2]**, evacuation plans not required for temporary stands, **[NFPA 1124 7.6.2.2]**
- 11) Tents, membrane structures and canopies >3 exits **[NFPA 1124 7.3.14.1.1]**, temporary stand retail areas >2 exits. **[NFPA 1124 7.6.2.3.1]**
- 12) Exits located such that all points are 100ft from an exit in tents, canopies and membrane structures **[NFPA 101 3103.12.1]** 35ft maximum egress travel in a temporary stand. **[NFPA 1124 7.6.2.3.2]**
- 13) Aisles
  - a. 48in minimum aisle width. **[NFPA 1124 7.3.14.3.1.1]**
  - b. 28in in temporary stands where the interior is not open to the public. **[NFPA 1124 7.6.4.1]**

**CARTERSVILLE FIRE DEPARTMENT**

c. Dead end aisle not permitted. <b>[NFPA 7.3.14.3.2.4]</b>	
14) Exit signs not required to be illuminated in tents <b>[NFPA 1124 7.4.8.3]</b> , stands, or stands open after dusk, and where interior of stand is not accessible to the public. <b>[NFPA 1124 7.6.2.3.4]</b>	
15) Emergency lights not required in tents <b>[NFPA 1124 7.4.8.4]</b> , or stands open after dusk, and where interior of stand is not accessible to the public. <b>[NFPA 1124 7.6.2.3.4]</b>	
16) Exit openings from tents have a minimum clear width of 44in <b>[NFPA 1124 7.4.8.5]</b> , 28in in temporary stands where the interior is not open to the public. <b>[NFPA 1124 7.6.4.2.1]</b>	
17) Every egress doors that latch provided with panic hardware. <b>[NFPA 1124 7.3.14.2]</b>	
<b>Exception</b> : temporary stand where interior is not open to the public. <b>[NFPA 1124 7.6.4.2.2]</b>	
<b>PORTABLE GENERATORS</b>	
18) Class II and Class II combustible liquid generator fuel limited to not more than 5gal. <b>[NFPA 1124 7.3.18.1]</b>	
19) Generator shall only use Class II or Class III fuel. <b>[NFPA 1124 7.4.9.2.1]</b>	
20) Generators and Class II or Class III fuel shall be located >20ft from CFRS facilities. <b>[NFPA 1124 7.4.9.2]</b>	
21) Unlimited amount of fuel allowed where generator fuel is stored >50ft CFRS facilities. <b>[NFPA 1124 7.4.9.2.4]</b>	
<b>DISPLAY REQUIREMENTS</b>	
22) Merchandise displays not higher than 6ft. <b>[NFPA 1124 7.3.15.2]</b>	
23) Merchandise displays located along perimeter of retail sales are max. height of 12ft. <b>[NFPA 1124 7.3.15.2.2]</b>	
24) Temporary CFRS stands where interior is not accessible to the public, display heights limited to 8ft. <b>[NFPA 1124 7.6.4.3]</b>	
25) Covered fuse fireworks only, permitted in retail sales areas. <b>[NFPA 1124 7.3.15.5.1]</b>	
<b>Exception</b> : temporary stand where interior is not open to the public. <b>[NFPA 1124 7.6.4.5]</b>	
26) Temporary stand where interior is not open to the public <b>[NFPA 1124 7.6.4.6]</b> :	
a. Fireworks displayed such that it prevents handling by the public.	
<b>Exception</b> : packaged assortments, boxes, or similarly packaged containers.	

<sup>1</sup> The above is not an all-inclusive list; all applicable fire and life safety provisions must be met.

<sup>2</sup> Mercantile Certificate of occupancy required Per NFPA 1124 Section 7.2.3

Notes: \_\_\_\_\_

\_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_

Reviewer: \_\_\_\_\_ Date: \_\_\_\_\_