



## Fire Alarm Checklist<sup>1</sup>

Job Name: \_\_\_\_\_  
 Address: \_\_\_\_\_ Suite: \_\_\_\_\_  
 City: \_\_\_\_\_ Zip: \_\_\_\_\_  
 Responsible Party: \_\_\_\_\_ Phone: \_\_\_\_\_  
 Fire Alarm Company: \_\_\_\_\_ Phone: \_\_\_\_\_  
 License # and level: \_\_\_\_\_

### GENERAL BUILDING INFORMATION:

Occupancy Type: \_\_\_\_\_ Occupant Load: \_\_\_\_\_  
 New System ☐ Tenant Remodel ☐ Replacement ☐  
 Fire Sprinklers Y ☐ N ☐ Voice Evacuation Y ☐ N ☐ Fire Pump Y ☐ N ☐  
 Special Locking Arrangements<sup>2</sup> Y ☐ N ☐ Other (explain) \_\_\_\_\_

✓ = Pass, X = Fail, NA = Not applicable

### Status

### DRAWING SUBMITTAL REQUIREMENTS

Provide (3) sets of drawings, (1) set of technical data (cut) sheets, voltage drop calculations, battery calculations, and a scope of work letter or description.

Drawings must be to scale

Label all rooms

Provide a legend/key for all fire alarm components and include the quantities; the symbols shall comply with NFPA 170 **7.2.3**

Indicate the person responsible for the system design on the plans **7.2.2**

Provide a copy of the low voltage license with name, license#, and signature of the license holder on the plans

Provide a riser diagram **7.2.1(2)**

Provide a sequence of operation in an input/output matrix **7.2.1(4)**

Provide a wire legend (wire type and size), show point to point system wiring, and end of line resistors (EOLR) locations. Signaling line circuits (SLR), notification appliance circuits (NAC) or other circuits are preferred to be shown in different colors

Provide penetration details for fire barrier/walls or smoke barriers; indicate is wiring is in a plenum space

Show the location of the fire alarm control panel (FACP) and any remote power supplies with smoke detectors <sup>3</sup>

Show the location of fire alarm documents cabinet for all new fire alarm systems **7.7.2**

Show the location of the fire alarm annunciator; annunciator must be within 10 feet of the main entrance or approved location by the AHJ

### INITIATING DEVICES

Show the location of manual fire alarm boxes; within 5 feet of exit doors **17.15.9.4**; provide additional manual pull boxes every 200 feet of travel **17.15.9.5**

Show the location of smoke detectors where required by NFPA 72 and/or NFPA 101. **Non-required smoke detectors should not be installed**

Show the location of duct detectors. **Duct detectors shall report as supervisory only 17.7.5.5**

Show the location of other smoke sensing detectors (i.e. beam detectors or air sampling smoke detectors)

Show the location of smoke detectors for the operation of smoke dampers

Show the location of heat detectors in elevator shafts and other locations required by code or weather conditions **17.6.1**

Show the interface with kitchen hood/automatic suppression systems **17.14**

Show the location of sprinkler flow switches for electronic monitoring **17.13, Cartersville Ordinance Ch.9 Article III Fire Prevention Code**

Show the location of any other automatic extinguishing systems (i.e. clean agent, CO<sub>2</sub>, foam, etc.) **17.14**

Show the location of all tamper switches for electronic monitoring of all sprinkler control valves including the PIV **17.17.1, Cartersville Ordinance Ch.9 Article III Fire Prevention Code**

Provide pressure supervisory signal initiating device and off normal signal for pressure increases and decreases in dry pipe sprinkler systems **17.17.2**

Provide fire pump monitoring per NFPA 20 to include pump running, loss of phase, and phase reversal **23.8.5.9**

|   |  |
|---|--|
| <b>NOTIFICATION APPLIANCES</b>  |  |
| Provide audible notification to attain 15 dB above average ambient sound level throughout the building or space <b>18.4.4.1</b> The sound level must be noted on the drawing <sup>4</sup>   |  |
| Where approved by the AHJ, audible notification sound levels may be reduced or eliminated with visual signaling devices <b>18.4.4.2</b>   |  |
| Provide audible notification at a minimum of 75 dB at the pillow level in sleeping areas <b>18.4.6.1</b> <sup>4</sup>   |  |
| Provide audible notification that produces low frequency alarm signals in sleeping and living areas <b>18.4.6.3</b>   |  |
| Show the location of speakers with wattage tap where the building is required to have a Fire Emergency/Alarm Communication System(i.e. assembly occupancies with occupant load over 300 or high rise buildings)   |  |
| Provide a note on the drawing stating the intelligibility of the voice evacuation system will meet the requirements of NFPA 72 Chapter 18 <b>24.4.2.2.2</b>   |  |
| Show the location of visible appliances and indicate the candela rating   |  |
| Show the height of strobes above finished floor mounted on the wall <b>18.5.5.1</b>   |  |
| Indicate the ceiling height for ceiling mounted strobes   |  |
| Provide strobe spacing in rooms per Table 18.5.5.5.1(a) and Figure 18.5.5.5.1 or Table 18.5.5.5.1(b) <b>18.5.5.5.1</b>  |  |
| Provide a note on the drawing regarding strobe synchronization where two or more strobes are in the same field of vision <b>18.5.5.5.2 (3), 18.5.5.6.7</b>  |  |
| Locate strobes in corridors not more than 15 feet from the end of the corridors and not more than 100 feet between strobes <b>18.5.5.6.5</b> Corridors wider than 20 feet must use the spacing requirements for rooms in accordance with <b>18.5.6.4</b>  |  |
| Provide strobes in sleeping areas where required per Table <b>18.5.5.8.3, 18.5.5.8.3</b>  |  |
| <b>EMERGENCY CONTROL FUNCTION INTERFACES</b>  |  |
| Provide initiating devices in areas for elevator recall as required by ANSI/ASME A17.1/CSA B44 <i>Safety Code for Elevators and Escalators</i> <b>21.3</b>  |  |
| Provide lobby smoke detector within 21 feet of the centerline of the elevator bank for elevator recall <b>21.3.5.1</b>  |  |
| Smoke detectors shall not be installed in unsprinklered elevator hoistways unless they are installed to activate the elevator smoke relief equipment <b>21.3.6</b>  |  |
| Show the location of all doors on hold opens with compliant smoke detector location per NFPA 72 <b>17.7.5.6 21.8</b> Note: Smoke detectors for door release to only report as supervisory signal  |  |
| Show the location of electrically locked doors (i.e. magnetic locks or access controlled doors) <b>21.9</b>   |  |
| <b>SUPERVISING STATION ALARM SYSTEMS</b>  |  |
| Provide a note on the drawing stating that the fire alarm system will be monitored by a supervising station for electronically monitored sprinkler systems and in buildings or occupancies required to have emergency forces notification. All fire sprinkler systems must be monitored by central station monitoring <b>Cartersville Ordinance Ch.9 Article III Fire Prevention Code</b> |  |
|   |  |
|   |  |

<sup>1</sup> **The above is not intended to be an all-inclusive list, all applicable codes for fire alarm systems must be met.**

<sup>2</sup> **Special locking arrangements include access control doors, delayed egress locks, and elevator lobby exit access door assemblies.**

<sup>3</sup> **A key plan must be maintained at each FACP and the sprinkler riser room where multiple FACP's on the premises are connected to a single flow switch.**

<sup>4</sup> **An audible sound level test report may be required to be provided to the inspector.**

Notes: \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_

Provide contact information for person responsible for completing the plan review form below:

Reviewer: \_\_\_\_\_ Phone: \_\_\_\_\_ Date: \_\_\_\_\_

